

5'

NOTES: ALL WIRING MUST CONFORM WITH THE NATIONAL ELECTRIC CODE AND ALL

LOCAL CODES.

PLEASE LEAVE 6' EXCESS CONDUCTOR FOR POLE APPLICATION

METER LOOP MUST BE FULLY ASSEMBLED FROM WEATHERHEAD TO DISCONNECT AND LAYING AT JOB SITE.

PLEASE ALLOW 2' OF GROUND WIRE TO EXTEND FROM DISCONNECT ENCLOSURE. EGYPTIAN ELECTRIC WILL CONNECT METER LOOP TO POLE. APPLICATION OF OXIDE INHIBITING COMPOUND IS REQUIRED WITH THE USE OF ALUMINUM CONDUCTORS.

ALL SHARP EDGES ON INSIDE ENDS OF CONDUIT MUST BE REAMED AND MADE SMOOTH.

NEC 250.32B STATES A FOURTH INSULATED WIRE IS REQUIRED FROM THE BREAKER ON POLE TO ALL MAIN PANELS FOR GROUNDING ALL **DWELLINGS & BUILDINGS** 100 AMP SERVICE #8 CU OR #6 AL 200 AMP SERVICE #6 CU OR #4 AL

MATERIAL LIST						
MATERIAL		QUANTITY				
		SINGLE PHASE	THREE PHASE			
Α	CONDUCTOR	AS NEEDED	AS NEEDED			
В	WEATHERHEAD	1	1			
	RIGID GALV. CONDUIT OR ALUM	15 FEET ON NORMAL POLE				
С	(PVC IS NOT ALLOWED)	CONTACT ENGINEERING				
D	2 HOLE CONDUIT STRAPS	4	5			
E	HUB - PROVIDED BY EECA	1	1			
F	METER BASE - PROVIDED BY EECA	1	1			
G	BONDING JUMPER	1	1			
Н	BONDING BUSHING	1	1			
I	GALVANIZED NIPPLE	1	1			
J	LOCKNUT	2	2			
K	HUB	1	1			
L	WEATHERPROOF DISCONNECT	1	1			
М	GROUND WIRE	3'	3'			

CONDUCTOR SIZING							
SERVICE SIZE	TYPE CONDUTOR	CONDUIT SIZE	SIZE GROUND CONDUCTOR				
100 AMP	#4 CU or #2 AL	1 1/4"	#6 BARE CU				
200 AMP	2/0 CU or 4/0 AL	2"	#4 BARE CU				
200 AMP 3Phase	3/0 CU or 250 AL	2 1/2"	#4 BARE CU				
*********NO REDUCED NEUTRAL ALLOWED************************************							

METER INSTALLATION FOR ELECTRIC SERVICE					
FOURTHIN SUFFERING COORDERLY WE ACCOUNT ON	SCALE NONE	DATE	SUPERSEDES	FILE NO.	
EGYPTIAN ELECTRIC COOPERATIVE ASSOCIATION	DRAWN BY HERMETZ	1/13	REV# 3 - 6/15/2007	FIGURE 4	
STEELEVILLE, ILLINOIS	SUPERCEDES		APPROVED BY	I IGONE 4	